



Texas Department of State Health Services

LABORATORY SERVICES SECTION, MC-1947
 1100 W. 49th St., Austin, Tx. 78756 (512)458-7587

PO BOX 149347
 AUSTIN, TEXAS 78714-9347
 1-888-963-7111
 www.dshs.state.tx.us

***ALL METALS
 Analysis Report**

Submitter Identification Number: 2460027

HIGH GABRIEL WSC
 PO BOX 130
 LEANDER, TX 78646-0130

Date Reported : 05/20/2014
 Report ID# : 20140520090831AC52577

Lab Sample ID# : AC52577
 Sample Priority : NORMAL
 TCEQ ID#(s) : 1415680

Water Source :
 Entry Point(s) : EP001

Date Collected : 05/01/2014 08:24
 Date Received : 05/02/2014

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	05/02/2014	JK
pH Check	Completed		EPA 200.2	05/05/2014	JK
Turbidity Screen	Completed		SM 2130B	05/05/2014	JK
Visible Particles	Completed			05/05/2014	JK
Total Hardness as CaCO3 by Calculation	207	mg/L	SM 2340B	05/07/2014	JK
Aluminum ¹	< 0.0200	mg/L	EPA 200.8	05/12/2014	PG
Antimony ¹	< 0.0010	mg/L	EPA 200.8	05/12/2014	PG
Arsenic ¹	< 0.0020	mg/L	EPA 200.8	05/12/2014	PG
Barium ¹	0.0846	mg/L	EPA 200.8	05/12/2014	PG
Beryllium ¹	< 0.00080	mg/L	EPA 200.8	05/12/2014	PG
Cadmium ¹	< 0.0010	mg/L	EPA 200.8	05/12/2014	PG
Calcium	40.4	mg/L	EPA 200.7	05/07/2014	JK
Chromium ¹	< 0.0100	mg/L	EPA 200.8	05/12/2014	PG
Copper ¹	< 0.0020	mg/L	EPA 200.8	05/12/2014	PG
Iron ¹	0.059	mg/L	EPA 200.7	05/07/2014	JK
Lead ¹	< 0.0010	mg/L	EPA 200.8	05/12/2014	PG
Magnesium ¹	25.7	mg/L	EPA 200.7	05/07/2014	JK
Manganese ¹	0.0011	mg/L	EPA 200.8	05/12/2014	PG
Mercury ¹	< 0.00040	mg/L	EPA 245.1	05/13/2014	JK
Nickel ¹	< 0.0010	mg/L	EPA 200.8	05/12/2014	PG
Potassium ¹	11.3	mg/L	EPA 200.7	05/07/2014	JK
Selenium ¹	< 0.0030	mg/L	EPA 200.8	05/12/2014	PG
Silver ¹	< 0.0100	mg/L	EPA 200.8	05/12/2014	PG
Sodium ¹	91.1	mg/L	EPA 200.7	05/07/2014	JK
Thallium ¹	< 0.00040	mg/L	EPA 200.8	05/12/2014	PG
Zinc ¹	0.0355	mg/L	EPA 200.8	05/12/2014	PG

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 05/16/2014