

**High Gabriel Water Supply Corporation
Regular Monthly Meeting Minutes August 13, 2018
Home of Aharon Kreiter**



Meeting called to order @ 7:05 PM
Attendance: Aharon Kreiter, Sue Couchman,
Aron Kloesel, Chuck Trahan, Kyle Smith

Absent: Dan Brent, Denny Springer

A motion to approve May minutes was made by Aharon, second by Chuck T.
Motion passed 4-0-1.

System Report: Terry Tuttle

June 2018 Total Gallons Pumped:	2,486,400
June 2018 Total Gallons Billed:	2,194,371
June 2018 Percent Loss:	12%
July 2018 Total Gallons Pumped:	2,354,200
July 2018 Total Gallons Billed:	2,270.015
July 2018 percent Loss:	4%

Bills Submitted:

- Centex #1 well – 2 motors(\$1949 each) and install (Total \$10722.56) motions - Aharon & Kyle – 5-0-0
- Centex - surge protector (\$1199.31) motions – Aharon & Chuck T. – 5-0-0
- June 20th lost well #1
- Centex replaced motor and wiring. 1st motor burned up at approx. 1million gallons, 2 motor installed – burned up in a few hours, 3rd motor installed and surge protector
- Determined that rewire is needed for well #1, was make shift 3 phase 240v
- PEC replaced all transformers to the wells with actual three phase, 208v – no charge
- well #1 motor will have to be changed out from a 240v to a 208v motor
- well# 1 hooked to a generator until 208v motor gets here and is installed (ran 10 days full time at 40gal/min)
- well #3 went down 8-9-18 over night – motor and wire damaged
- well #3 pump tested on 8-11-18, wire supply to the well replaced to eliminate approx. 100ft, well #2 no longer on the system
- well #3 installed and hooked up, running 130 – 150 gal/minute – that is as much as previous 2 wells combined. Well #3 level 480ft. Well #1 turned off until new 208v motor could be installed and water level 500 ft. well #3 has new fuse panel, motor, wiring, still old pump and control box

Treasurer’s Report: Chuck Trahan presented the monthly Treasurer’s report.
The report was accepted without comment.

Aron brought up helping Aharon with duties, discussion was that no help was needed.
A motion to adjourn was made at 7:39 PM - Motion passed 5-0-0.